



Product Service

CERTIFICATE

No. Z2 101002 0005 Rev. 01

Holder of Certificate: TSEC CORPORATION

8F, No.225, Sec 3, Beixin. Rd.
Xindian Dist.
23143 New Taipei City
TAIWAN

Certification Mark:



Product:

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Mono-crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062475403-01

Valid until: 2030-05-06

Date, 2025-05-07

(Zhulin Zhang)

CERTIFICATE

No. Z2 101002 0005 Rev. 01

Model(s):

TS72-CMH-xxx H2 (xxx=570-605 in steps of 5W)
 TS66-CMH-xxx H2 (xxx=525-555 in steps of 5W)
 TS60-CMH-xxx H2 (xxx=475-505 in steps of 5W)
 TS54-CMH-xxx H2 (xxx=425-455 in steps of 5W)
 TS72-CMH-xxx H1 (xxx=570-605 in steps of 5W)
 TS66-CMH-xxx H1 (xxx=525-555 in steps of 5W)
 TS60-CMH-xxx H1 (xxx=475-505 in steps of 5W)
 TS54-CMH-xxx H1 (xxx=425-455 in steps of 5W)
 TS48-CMH-xxx H1 (xxx=380-405 in steps of 5W)
 TS42-CMH-xxx H1 (xxx=330-355 in steps of 5W)
 TS36-CMH-xxx H1 (xxx=280-305 in steps of 5W)
 TS30-CMH-xxx H1 (xxx=230-255 in steps of 5W)
 xxx is standing for rated output power at STC

Parameters:

Safety Class:	Class II
Max. System Voltage:	1500V DC
Test Laboratory:	Telecom Technology Center Communication and Photovoltaic Laboratory Telecom Technology Center No.3, Luke 1'st Rd., Lujhu, Kaohsiung city, Taiwan CHINESE TAIPEI
Construction:	Framed, with Junction box, cable and connectors.
Fire Safety Class:	Class C according to UL790

Tested according to:

IEC 61215-1:2021
 IEC 61215-1-1:2021
 IEC 61215-2:2021
 IEC 61730-1:2023
 IEC 61730-2:2023